

**Abstimmung Sicherung und Lasttrennschalter, [kA], ( $\leq 500$  VAC)**

	Lastseite								
	OT16M	OT25M	OT40M	OT45M	OT63M	OT80M	OT100M	OT125M	OT160M
gG 25A	50	50	50	50	50	50	50	50	50
gG 32A	30	50	50	50	50	50	50	50	50
gG 40A	20	30	50	50	50	50	50	50	50
gG 50A	10	20	30	50	50	50	50	50	50
gG 63A	6	10	20	50	50	50	50	50	50
gG 80A		6	10	50	50	50	50	50	50
gG 100A			6	30	30	30	30	50	50
gG 125A				16	16	16	16	40	50
gG 160A				10	10	10	10	30	50
gG 200A				6	6	6	6	16	50

Einspeiseseite

gG 25A  
gG 32A  
gG 40A  
gG 50A  
gG 63A  
gG 80A  
gG 100A  
gG 125A  
gG 160A  
gG 200A